



Factssheet Tankfarm Essen



Tank allocation

- 97,400 m³ Light Heating Oil (LHO) and Automotive Diesel Oil (ADO)
- 8,000 m³ motor Gasoline (MoGas)
- Heatable storage tanks are also available

Filling position/Unloading and loading rate

- Discharge rate for MoGas from barge 300 m³/h
 - Discharge rate for LHO/ADO from barge 250 m³/h
 - Loading rate for LHO/ADO on barges and tank wagons 150 – 300 m³/h
 - 4 x bottom loading for MoGas on truck at 2 tracks
 - 6 x bottom loading for ADO on truck at 3 tracks
 - 3 x top loading for LHO on truck at 3 tracks
 - 2 x top loading for ADO on truck at 2 tracks
- Loading rate on truck 120 m³/h

Other

- Energy tax warehouse
- Liquor tax warehouse
- Admixing of biodiesel fuel
- Additivation of ADO
- Ethanol endpoint dosing
- Remote data transfer using the MPKS format

Warehouse custom codes

Warehouse custom code DE00001967258

Warehouse owner custom code DE00001967266